



**SERVICE SADDLE DETAIL**  
NTS

**NOTES:**

1. 1 SERVICE SADDLES FOR 1 INCH, 1-1/2 INCH & 2 INCH TAPS SHALL CONFORM TO AWWA C800 WITH A MINIMUM WORKING PRESSURE OF 150 PSI, UNLESS A HIGHER PRESSURE IS SPECIFIED, AND BE MANUFACTURED BY FORD, MUELLER, ROMAC, SMITH-BLAIR OR APPROVED EQUAL. (SEE DWG. C-3.2.1 FOR ADDITIONAL NOTES AND DETAILS.) POTABLE SERVICE SADDLES SHALL BE LOW LEAD CONTENT AND IN COMPLIANCE WITH NSF61 AND NSF 372.
2. SERVICE SADDLES SHALL BE FACTORY COATED DUCTILE IRON (ASTM A395 OR A536) WITH TYPE 18-8 STAINLESS STEEL (304 OR 304L) STRAP(S), BOLTS, NUTS, & WASHERS. ALL STAINLESS STEEL SHALL BE FULLY PASSIVATED.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
<span style="float: left;">1</span>	NOTE 1	9/17	<b>1" TO 2" SERVICE SADDLE</b>	CARSON CITY
				DRAWING NO. C-3.2.2 (203, 307)
				DATE SEP 2017
APPROVED BY:		9/17		