


SECTION A-A
NTS

NOTES:

1. MINIMUM CURB RETURN RADIUS SHALL BE 15 FEET UNLESS OTHERWISE APPROVED BY THE CARSON CITY ENGINEER OR PUBLIC WORKS DIRECTOR.
2. SOME STREETS MAY REQUIRE WIDER SIDEWALKS.
- 1 3. SIDEWALK ADJACENT TO TYPE 2 OR ROLLED CURB AND GUTTER SHALL BE CONSTRUCTED 5 INCHES THICK OF CONCRETE ON 6 INCHES OF AGGREGATE BASE COMPACTED TO 95%
- 1 4. SIDEWALK SHALL BE POURED NON-MONOLITHICALLY FROM CURB AND GUTTER.
- 2 5. TRANSVERSE EXPANSION JOINTS SHALL BE PLACED PER DETAIL C-5.1.1 AT GRADE BREAKS, TANGENT POINTS, ANGLE POINTS AND AT REGULAR INTERVALS NOT EXCEEDING 30 FEET.

NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	NOTE 3 & 4	9/17	TYPE "A" SIDEWALK	CARSON CITY
2	NOTE 5	1/21		DRAWING NO. C-5.2.2
APPROVED BY: 				DATE JAN 2021